

DIGITALES ARCHIV

ZBW – Leibniz-Informationszentrum Wirtschaft
ZBW – Leibniz Information Centre for Economics

Wasiu Olalekan Idris; Mohd Zamri Ibrahim; Aliashim Alibani

Article

Prospects of solar energy exploration in Nigeria : assessments, economic viability and hybrid system

Provided in Cooperation with:

International Journal of Energy Economics and Policy (IJEPP)

Reference: Wasiu Olalekan Idris/Mohd Zamri Ibrahim et. al. (2024). Prospects of solar energy exploration in Nigeria : assessments, economic viability and hybrid system. In: International Journal of Energy Economics and Policy 14 (2), S. 676 - 686.

<https://www.econjournals.com/index.php/ijeep/article/download/14977/7825/36498>.

doi:10.32479/ijeep.14977.

This Version is available at:

<http://hdl.handle.net/11159/653417>

Kontakt/Contact

ZBW – Leibniz-Informationszentrum Wirtschaft/Leibniz Information Centre for Economics

Düsternbrooker Weg 120

24105 Kiel (Germany)

E-Mail: [rights\[at\]zbw.eu](mailto:rights[at]zbw.eu)

<https://www.zbw.eu/econis-archiv/>

Standard-Nutzungsbedingungen:

Dieses Dokument darf zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden. Sie dürfen dieses Dokument nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, aufführen, vertreiben oder anderweitig nutzen. Sofern für das Dokument eine Open-Content-Lizenz verwendet wurde, so gelten abweichend von diesen Nutzungsbedingungen die in der Lizenz gewährten Nutzungsrechte.

<https://zbw.eu/econis-archiv/termsfuse>

Terms of use:

This document may be saved and copied for your personal and scholarly purposes. You are not to copy it for public or commercial purposes, to exhibit the document in public, to perform, distribute or otherwise use the document in public. If the document is made available under a Creative Commons Licence you may exercise further usage rights as specified in the licence.



Prospects of Solar Energy Exploration in Nigeria: Assessments, Economic Viability and Hybrid System

Wasiu Olalekan Idris^{1,2}, Mohd Zamri Ibrahim^{1,2*}, Aliashim Albani^{1,2}

¹Renewable Energy and Power Research Interest Group, Eastern Corridor Renewable Energy, Universiti Malaysia Terengganu, 21030, Kuala Terengganu, Terengganu, Malaysia, ²Faculty of Ocean Engineering Technology and Informatics, Universiti Malaysia Terengganu, 21030, Kuala Terengganu, Terengganu, Malaysia. *Email: zam@umt.edu.my

Received: 08 August 2023

Accepted: 18 February 2024

DOI: <https://doi.org/10.32479/ijeep.14977>

ABSTRACT

The recent happenings in the world such as flood and wild forest fire were as a result of climate effect as being envisaged by scientists. It is urgent now to adopt a source of energy that will eliminate this effect on our universe. Solar energy is the major energy means that is abundant which could be utilized. In this review, the prospects of solar energy exploration were studied in Nigeria which include assessments, economic viability and hybrid systems. Findings show higher potential in the North as compared to the Southern region. Additionally, potential of offshore solar energy system was simulated by considering 2002-2021 data sets (20 years) from Era5-land base. Their monthly mean, seasonal changes and annual mean value were estimated. The algebraic annual solar radiance for 2002 and 2003 were highest valued at 34,914.732 kWhm⁻² while the least occurred in 2008 as 26,967.168 kWhm⁻². Suggestions were made due to the present status of solar energy utilization that will enhance its maximum usage and development. One of these is the establishment of a functioning financial scheme and the database for all renewable energy systems. When all these are put in place, the energy supply will increase, climate effect will be reduced, and the economy will be boosted.

Keywords: Solar Photovoltaic System, Renewable Energy System, Solar Radiation, Net Present Value, Cost of Electricity

JEL Classifications: A12,C81,E22, G18, O21,K32

1. INTRODUCTION

The need for Adoption of renewable energy systems is of important based on day-to-day activities that require energy that capable of avert negative effect of global warming and all stakeholders must involve to realize this milestone (Luo et al., 2023). The potential of Solar energy systems is of immense benefit in curtailing the effect of climate change and thus aligned with Paris Agreement (Nwokolo et al., 2023). The advent of Solar energy system as one of renewable energy sources which has capacity to replace fossil fuel that have causes various environmental hazard is a laudable goal (Liu et al., 2021) (Abdelrazik et al., 2022). Efficiency of a solar energy has been proven to be higher in comparison with other renewable energy means that is economically viable as well as its availability (Wang et al., 2021). The continuous utilization

of renewable energy power systems has driven their operation and maintenance costs to a lower trend providing room for avoidable, reliable and competitive renewable energy generation techniques (Abu-Rayash and Dincer, 2021). The use of solar energy power from sunlight occur by sun heating the surface of photovoltaics (PVs) cell which resulted into photo- electric emission that can be employed for electricity generation or heating of fluid for industrial purposes (Wu et al., 2020) (Agbo et al., 2021). The accuracy of the solar irradiance at a specific areas is utmost importance in the deployment of solar energy-based systems design (Muzathik et al., 2011). Currently, the solar energy serves as foremost reliable renewable energy sources that possess up to 23,000 TW available energy storage on a yearly basis and also adequate to meets the global energy demanded (Wu et al., 2020). It had been estimated that the worldwide installation capacity as refer to solar energy

PV as at 2016 amounted to hourly deployment of 31,000 panels globally (Ayodele et al., 2021). The solar energy potential available in Nigeria amounted to 3.5-7.5 kWhm⁻²/day with corresponding value of 145.83-312.50 Wm⁻² (Ozoegwu and Akpan, 2021). Additionally, the mean for yearly estimation was found to be 1770 thousand TWh/year (Ohunakin et al., 2014). The determination to incorporate large solar PV system into Nigeria grid system will pave way for mutual benefits for both ECN (Energy Commission of Nigeria and the IAEA (International Atomic Energy Agency) that target for capacity building in a bid to strategize and plan for energy needs (Ogunjuyigbe et al., 2021). Although, Nigeria electricity supply is insufficient for electricity demand. The increase in population is very rapid, the pipe vandalism and decaying of existing electricity contributed to present predicament of power sector in Nigeria. The paradigm shifts to renewable energy system like solar, wind, wave, biomass and other renewable energy means will supply the needed energy even in excess. This work dedicated to solar energy system review in Nigeria to depicts the stages of its development in terms assessment of solar radiance, economic effect of solar energy, hybrid configuration. Literatures were searched from science direct, web of science, google scholar, research gate and springer link by search "solar energy in Nigeria." Thereafter, the studies were streamline in terms of area of specialization of the study which includes assessment, economic and hybrid system. The gaps were enumerated, and recommendations was provided that will pave way for accessing these enormous potentials. Based on gap identify, none of the literatures explore the potential of offshore solar energy system which was assessed on this paper that can serve as hybrid system with wind energy system or standalone.

2. ASSESSMENT OF SOLAR IRRADIANCE IN NIGERIA

The establishment of sufficient studies in order to assess the solar radiation in any part of the world is necessary ingredient for successful deployment of efficient solar PV system. Several literatures on assessment of potential solar radiation across Nigeria were scrutinized to reflect the present status of solar renewable energy in different locations and their viability. The estimation of global solar irradiance was carried out ranged 1997-2007 by adopting general circulation model for change in season and annual variation (Ohunakin et al., 2015). The trends of concentration solar power potential were reviewed that could be achieved in near time, midterm and long duration. It was suggested that adequate political will could assist in attained the milestone and the existing oil and gas firm should explored this viable renewable energy (Ogunmodimu and Okoroigwe, 2019). Analysis of solar resources in three commercial urban areas (Lagos, Onitsha and Kano) was assessed. The potential in Kano was found to be higher (6.08 kWhm⁻²) compare to Lagos and Onitsha (4.42 kWhm⁻²) (Okoye et al., 2016). Moreover, the prospect of solar energy policy as enacted in Nigeria renewable energy policy was scrutinized in other to reflect the gaps present. The outcome shows the need to adopt new law that could cater for solar wastes deposit in order to avoid environmental hazards as well as health of people in the communities (Ozoegwu and Akpan, 2021). The potential of rooftop solar PV system was examined in this research for

Ibadan city by reduction factor technique using population census, imagery map and ArcGIS software. Maximum installation capacity obtained was 1734 Mwp covering 7.50 square kilometres at an optimized tilt angle of 11° (Ayodele et al., 2021). Another study expresses the present status of solar application and resources estimation was conducted for Nigeria sites which shows higher radiation in the Northern part compare to Southern areas (Agbo et al., 2021). The growth in energy demand and global concern about the environment has resulted in the drive towards alternative energy sources and consequently this research concerning solar energy harvesting of radiation received at the earth's surface. In the calculation of solar radiation resources for Portharcourt, Maiduguri and Minna, the larger value depicted in Maiduguri in respect to other two sites; 1219489.32 Wp, 619419.27 Wp, 821142.52 Wp accordingly (Abdulkarim et al., 2020). Saliu et al. describes the installation and designed of micro-grid solar energy in Lajolo rural community as means to boost the economy as well as health status of the occupant of this community (Salihu et al., 2020). According to scholarly work done on Metropolitan area of Lagos State, result shows lead acid capacity of 2-176 kWh, PV modules ranges 0.3-76 Kw and inverter size 0.1-13.2kW (Enongene et al., 2019).

These research activities involve review of existing studies which confirmed nearly no literature on artificial intelligent and exploration of artificial neural networks to estimate solar energy in Enugu as pilot study in Nigeria. The system predicts solar potentials using time series technique that shows higher precision than empirical analysis (Ozoegwu, 2018). One of the studies lay emphasis on integrating tracking system on solar energy generation by adopting two-axis tracking in Nigeria. It was asserted that extra energy amounted to 20-40% could be obtained in regard to non-tracking system when solar irradiation and ambient temperature were employed (Njoku, 2016). A 6 MW solar power grid connected system was examined in North-east region to find the extent of viability in terms of technology, environmental effect as well as economic implication using RETScreen Expert software. The outcome shows that all sites are viable and Yobe state has highest potential (11,385 MWh) annually (Owolabi et al., 2019). Application of neuro-fuzzy inference was tested for solar radiation prediction in Iseyin, Oyo State using Nimets daily data for solar irradiation, sunshine and temperature. When compare the outcome with experimental result, there exist improvement in the performance and root mean square error achieved was 1.7852 on the testing phase (Olatomiwa et al., 2015). An empirical analysis was employed to calculate mean monthly global solar irradiation in horizontal direction for Makurdi, Benue State with the aid of Angstrom- page model over the range of 18 years daily data. The mean square error obtained was 1.22% (Yohanna et al., 2011). Weihao Hu in their study using Energy PLAN b suggested that hybridization of wind and solar energy in commercial scale will offset inadequacy demand of electricity generation in Nigeria (Bamisile et al., 2020). In order to employ the best modular solar PV system for grid-connected installation in Nigeria, not fewer than fourteen various solar manufacture modules were studied. The result shows the yield to be in the range of 4.0361-4.7972 kWh having performance ratio of 78.96-79.96% (O et al., 2021). Additionally, research was embarked in Umudike, Niger Delta area for solar energy resources illustration using Sayighr termed

Universal Formula. The output obtained was 1.99-6.75 kWh that in conformity with previous studies (Chineke and Okoro, 2010). Assessment of solar irradiation was conducted in Aghani urban area having annual mean value of 4.67 kWhm⁻² (Ene et al., 2021). The possibility of using hybrid energy system for electricity generation in rural and semi-urban areas in the Northern part of Nigeria was investigated in this study. An hybrid of solar energy system was explored in Jos, Plateau State, average annual solar global irradiation observed was 6 kWhm⁻² which shows solar/diesel generator/battery as most effective hybrid integration (Adaramola et al., 2014). A multi-vary objective optimization was employed in 3 rural community area of South-West for solar energy in order to reflect productive utilization in a domestic environment. Spanning period of 25 years, energy needed in three localities were obtained to be 28,280 kWh, 28,609 and 29,554 kWh with mean productive use of 0.338, 0.348 and 0.358 respectively (Akinyele et al., 2020). A solar PV system and wind energy were studied as hybrid system in the senate building (University of Ilorin), Kwara State using Energy Analyzer as well as Power Quality. It was observed that daily mean energy required for wet season, dry season and weekend days were 712 kWh, 1520 kWh and 213 kWh accordingly (Ariyo et al., 2018). The estimation of solar radiation in Porth-Harcourt, Sokoto and Ibadan was done for every 4 months in a year using ANOVA (Analysis of Variance). Another study explore phase synchronization in respect to solar radiation data and wind speed in latitude 3-14° (Adeniji et al., 2019). An integration of solar PV system into a National grid was analysed with the aim of maintaining stability in the system as well as minimizing the losses by adopting multi-objective optimization algorithm (Adewuyi et al., 2019). A related study was considered to ascertain what type of technology could be explored in deploring various renewable energy which reflect their economic value, environmental effect, social influence with the aid of multi-criterial technique. The conclusion made prove that solar PV system is most suitable electrification in Nigeria (Juanpera et al., 2020). Also, smart grid electricity system was evaluated in this study for rural community with a specific design approach. Then battery storage system, solar PV system and diesel generator set was considered that will make use of low-voltage efficient bulb and it was found to save up to 42-76% peak value of electricity demand. When tested with application of light emitting diode bulbs, it saves around 56-81% net present cost compare with diesel generating set having incandescent lighting (Nnaji et al., 2019). Ikejemba and Schuur adopted multi—step technique to design network for solar energy pack and wind energy pack in South-East region taking Anambra State as hub site for the study (Ikejemba and Schuur, 2016). Assessment of life cycle impact for solar PV system having rating of 1.5kWpaper was studied in all six region of Nigeria. The following factors were considered, global warming, emission rate, energy payback time cumulative energy demand as well as net energy ratio. The outcome show less global warming and energy payback time at a site with higher solar irradiance whereas larger in location of lower solar irradiance (Akinyele et al., 2017). Evaluation of a hybrid flat plate solar collector system and nocturnal radiator in respect to water heating was simulated in selected five urban areas. It was suggested that ambient energy depicts enormous potential to reduce energy security issues and still provide friendly

environmental condition (Nwaji et al., 2020). As for estimation of back temperature for solar modules, it was tilted at different angles of 26.80°, 16.80° and 6.70° was explored in Lagos State. The analysis shows energy gain amount to 19.49%, 20.84% and 8.74% as the angle decrease respectively (Obiwulu et al., 2020). Importantly, this research described the influence of solar eclipse (97%) that occurred in Oyo State in March 2006 (Nymphas et al., 2012). The grid-connected solar PV system was examined in Northern region of Nigeria by explored HOMER software optimization tool. Global solar daily radiation observed was 6.0 kWh/m per day having annual electricity generation of 331,536 kWh (Adaramola, 2014). The preference for solar charger in household was observed using a random parameter model with an outcome showing the respondents voted for high quality charger (Elegbede et al., 2021). In order to estimate the mean monthly solar radiation in Makurdi, Benue State, artificial neural network was explored which include radial basis function neural network, generalized regression method and feed forward neural network. It was concluded that all the neural networks perform maximally with mean square error of 0.0142 and square error of 0.998 on average basis (Kuhe et al., 2021). Additionally, the deployment of solar pumping system was studied in Ibadan city for abattoirs which depicts economic benefits (Ayodele et al., 2019). Another studies examine applicability of concentration solar power by adopting DESERTEC model for Nigeria solar radiation as it reflect beneficial to European countries (Akuru et al., 2015). This work utilized user- oriented software application for solar/hydrogen energy production. It encloses hydrogen cooking based load devices. The outcome suggested that solar PV module of 2.420 Kw, 3.70 kWh battery storage with 0.6 Kw electrolyser is sufficient for daily demand amounted to 2.2 kWh in a rural community (Onwe et al., 2020). Modelling the assessment of solar PV system in some designated cities was conducted by adopting six tracking system (single axis), inclined as well as dual base- axis tracking surfaces. Still Perez anisotropic and Koronakis isotropic technique were employed for component diffuse prior to combination of tracking system. The yearly solar potential for fixed inclination give 1621-2279 kWh/m² while that of solar tracking system shows 1664-2983 kWh/m² which are adequate in impacting on energy supply to the populace (Okoye et al., 2018). An assessment of solar PV system in combination with small hydro system was enumerated in Federal university of technology Owerri (FUTO) using 12 years solar data sets. The system give 98521098 Ah as capacity for battery bank with 3025 PV module covering area of 3248 m² would be most suitable configuration for site location (Ogueke et al., 2016). In order to formulate empirical model for global solar radiation in Ibadan city, three different models were explored which include Garcial, Angstrom-Prescott and Hargreaves- Sammani model. It was observed that Garcial quadratic technique serve as the best model which could forecast mean daily global solar radiance having root mean square error of 2.70 MJ/m² per day, mean absolute error amounted to 1.86 MJ/m² per day, coefficient of determination 0.68 and 9.34% mean absolute percentage error (Ayodele and Ogunjuyigbe, 2017). The rural communities in the coastal area of Niger- Delta area was simulated for solar PV system using hybrid optimization model software (HOMER) within a period of 22 years. Result depicted future electric energy demand of 8.83 kWh having cost of energy

0.653 \$ per kWh, existing energy demand amounted to 5.640 kWh with cost of energy 0.651\$ per kWh which also include future energy based demand of 7.233 kWh consist of 0.674 \$ per kWh cost of energy that all seem to be accurate, reliable clean energy system (Diemuodeke et al., 2017). More importantly, this study describe solar energy research in terms coordinated finance for investment that was systematic in deploring solar energy system in Nigeria (Okoro and Madueme, 2006). Oduola et al. evaluate the acceptance of solar PV system in Port Harcourt, River State by used AHC (Agglomerative Hierarchy Cluster) and logistic regression technique. An acceptance rate of 40.51% was obtained which is centred on unawareness level of 99% while rejection rate was 59.49% (Koyejo and Zorbarile, 2021). Similar study was done in Lagos State by considering medium and small enterprises by questionnaire method with the use of descriptive statistic and regression model. It was observed that inadequate accessibility to electricity, poor customer care as well as power outage from electricity distribution were not serve as main causes of the use of solar energy (Anaba and Olubusoye, 2021). Likewise, in South-West preference for use of solar PV system was illustrated based on respondents from available users and non-user with the aid statistic and regression analysis. Respondents admitted that solar energy was preferred alternative means of energy having mean score of 3.83 (Thompson et al., 2021). Also, a qualitative analysis was explored based on interview in form of semi-structured one-on-one to access barrier in the use of solar PV system in Nigeria.

This study suggested that barriers related to politics, technology, social factors and finance contributed to low solar utilization and development (Abdullahi et al., 2021). A household reflection on the installation of solar PV system was conducted via interview in Kano metropolitan area. Respondent were found to adopt solar energy for recharging purposes, cooling system and lighting (Barau et al., 2020). Then, a questionnaire was administered in Ibadan to show usage of solar PV system in Oyo State by considering schools, households and industries. The survey revealed that households and schools used solar for electronic devices while offices employing it for lighting and powering equipment with the exemption of air condition device. It must be emphasize that awareness is low for solar energy utilization (Ilori et al., 2020). Study was conducted on solar PV rooftop system in the primary health care facilities using analytical expression across 6 geopolitical zones. Annual available energy at the inverter output recorded highest in Kano State (6654.4 kWh) with the lowest value of 5363.1 kWh in Akwa Ibom. Summarily, Northern part possess higher solar radiance compare to Southern region (Chikwado et al., 2021). A geospatial analysis of solar PV system was conducted in eastern part of Nigeria by adopting multi- criteria decision analysis. Result show that 5900 hectares were appropriate for solar energy system (Chiemelu et al., 2021). In this study, an experiment procedure was followed to measure solar radiance on a daily base with the aid of light meter (LX101A) in North central part of Nigeria. It was realized that 29168.29 MW of solar energy spread over 0.1% of total mass land is available while mean minimum and maximum values were 2.70 kWh/m² and 7.50 kWh/m² respectively (Ndanusa, 2020). Analysis of daily solar radiance was done by means of Artificial Neural Network (ANN) spanned 20-year data set. The RMSE (Root mean square error) observed

was 0.470 and 0.480 as regard training and testing the network while their square error was 0.78 (Aliyu et al., 2020). In the other hand, mathematical modelling of off-grid solar PV system was examined in Jos, Plateau State on a residential building. Result depicted that battery capacity of 500 Ah each of 100 Ah, ten PV modules each value 275 Wp will meet yearly electricity demand of nearly 3132 kWh (Akinsipe et al., 2021). Availability of solar energy was studied in 25 sites across Nigeria based on solar PV system rating 100-MW by applying RETScreen application. It was deduced that Gusau possess highest annual electricity generation of 167,307 MWh with the least value of 108,309 MWh in Port Harcourt (Njoku and Omeke, 2020). Okoye et al. researched the solar energy PV system resources by means of Hargreaves and Samani technique in selected six sites in Nigeria for period of 10 years temperature data. The outcome depicts average global solar irradiation to be 19.83 ± 0.60 MJ/m², 18.55 ± 0.54 MJ/m² and 17.80 ± 0.30 MJ/m² for Maiduguri, Sokoto and Markurdi respectively compare to southern part namely; Awka, Ibadan and Port Harcourt that have 17.68 ± 0.28 MJ/m², 16.68 ± 0.36 MJ/m² and 17.46 ± 0.19 MJ/m² accordingly (Okoye et al., 2020).

Generally, the Northern section of the country shows larger solar radiation as compared to Southern part as enumerated in the above studies and depicted In Table 1 in terms of their location as well as specific analysis involved. It should be noted that there is absence of comprehensive Data based repository for global solar irradiance assessment in all cities and locations. This might be of immense benefits to scholars, government as well as investors on how best they can explore the abundant solar energy in Nigeria. It will in turns avert incessant power supply when adequately utilized. Additionally, over reliance on fossil fuel that has cause various hazards to the climate and the occupant of the earth can be easily reduced to minimum level. The government policy needs to be aligned to sustainable, adequate and clean energy for enhancement of renewable energy systems. Lack of political will had been the bottle neck for attained goals as highlighted in the millennium plans. Though Nigeria government partner with Worlds Bank on solar energy PV system that has brought tremendous developments and advantages compare to other renewable energy. On the part of higher institution of learning. Their programs should incorporate renewable energy studies as part of general courses, partner with various private company for projects in the communities, educate the populace about the benefits of renewable sources and incentives could be offered to scholars that contributed their knowledge to development of renewable energy. Therefore, needs for stakeholders involves in renewable energy to work together on achieving the stated recommendations.

3. ECONOMIC EVALUATION OF SOLAR ENERGY

Analysis of economic viability and applicability of solar PV system is a pivot for development of appropriate technology in different sites. So researchers decided to explore this platform in Nigeria context as outlined in this section. This paper conducted the economic effect of standalone solar PV system for off-grid rural areas using HOMER software up to 24 years' meteorological

Table 1: Summary of literatures on assessment of solar energy resources

Location	Designation	Source
Nigeria	General circulation model	(Ohunakin et al., 2015)
Nigeria	Concentration solar power	(Ogunmodimu and Okoroigwe, 2019)
Lasgos, Onisha, Kano	Analysis	(Okoye et al., 2016)
Nigeria	Policy	(Ozoegwu and Akpan, 2021)
Ibadan	Roof top PV	(Ayodele et al., 2021)
Nigeria	Analysis	(Agbo et al., 2021)
Porth Harcourt, Maiduguri, Minna	Analysis	(Abdulkarim et al., 2020).
Lajola rural community	Micro-grid	(Salihu et al., 2020)
Lagos State	Analysis	(Enongene et al., 2019).
Nigeria	Review/Analydsis	(Ozoegwu, 2018).
Nigeria	Tracking/Analysis	(Njoku, 2016)
North-East	Analysis	(Owolabi et al., 2019)
Iseyin, Oyo State	Analysis	(Olatomiwa et al., 2015).
Markurdi, Benue State	Analysis	(Yohanna et al., 2011).
Nigeria	Hybrid analysis	(Bamisile et al., 2020)
Nigeria	Analysis	(O et al., 2021)
Umudike, Niger-Delta	Analysis	(Chineke and Okoro, 2010).
Agbani	Analysis	(Ene et al., 2021).
Jos, Plateu State	Analysis/Mathematical modelling	(Adaramola et al., 2014) (Akinsipe et al., 2021).
University Ilorin, Kwara State	Analysis	(Akinyele et al., 2020).
Porth Harcourt, Sokoto, Ibadan	Analysis	(Ariyo et al., 2018).
Nigeria	Analysis	(Adeniji et al., 2019).
Nigeria	Analysis	(Adewuyi et al., 2019)
Nigeria	Analysis	(Juanpera et al., 2020)
Nigeria	Hybrid analysis	(Nnaji et al., 2019).
South- East	Energy pack	(Ikejemba and Schuur, 2016)
Nigeria	Analysis	(Akinyele et al., 2017).
Nigeria	Solar heating	[33]
Lagos State	Analysis	(Obiwulu et al., 2020).
Oyo State	Solar eclipse	(Nymphas et al., 2012).
Northern Nigeria	Analysis	(Adaramola, 2014)
	Questionnaire	(Elegbede et al., 2021).
Markurdi, Benue State	Analysis	(Kuhe et al., 2021).
Ibadan	Solar pumping	(Ayodele et al., 2019).
Nigeria	Concentration solar power	(Akuru et al., 2015).
Rural community	Solar/Hydrogen	(Onwe et al., 2020).
Major cities	Tracking/Analysis	(Okoye et al., 2018).
FUTO, Owerri	Solar/Hydro	(Ogueke et al., 2016).
Ibadan	Analysis	(Ayodele and Ogunjuyigbe, 2017).
Niger- Delta	Analysis	(Diemuodeke et al., 2017).
Nigeria	Solar investment	(Okoro and Madueme, 2006).
Porth Harcourt	Solar Acceptance	(Koyejo and Zorbarile, 2021).
Lagos State	Questionnaire	(Anaba and Olubusoye, 2021).
South-West	Questionnaire	(Thompson et al., 2021).
Nigeria	Interview/Qualitative	(Abdullahi et al., 2021).
Kano	Questionnaire	(Barau et al., 2020).
Oyo State	Questionnaire	(Ilori et al., 2020).
Nigeria	PV rooftop	(Chikwado et al., 2021).
Eastern Region	Geospatial analysis	(Chiemelu et al., 2021).
North Cenral	Solar experiment base analysis	(Ndanusa, 2020).
Nigeria	ANN analysis	(Aliyu et al., 2020)
Nigeria	Analysis	(Njoku and Omeke, 2020).
Selected Sites	Analysis	(Okoye et al., 2020).

data for 40 sites. The result shows that for 15 MW PV system, the levelized cost fall on \$ 0.01/kWh to \$ 0.17/kWh in twenty-nine sites (Ohijeagbon and Ajayi, 2015). A cost-effective way to install solar PV system was done for Lagos State by removing the adoption of diesel generation sets. Base on financial technique, a cost reduction of 60% was obtained for PV system in respect to usual diesel generator application (Babajide and Brito, 2021). Similar studies explore the hybrid of solar PV/diesel generator sets as regard its cost effectiveness for private company. It was asserted

that cost reduction of about € 0.002 with 0.009/kWh was observed (Adesanya and Schelly, 2019). The estimated values of PV capacity with their cost of electricity generation in three commercial cities (Lagos, Onitsha and Kano) were ranged from 1.26 kWp-2.92Kwp and 0.206-0.502 USD/kWh (Okoye et al., 2016). Assumed energy demand of 1.1 MWh was simulated for the cost viability of solar energy in three States capital in Nigeria. An incremental value cost of \$460,984.72 was detected in both Porth- Harcourt and Minna for the life span of the project compare to Maiduguri (Abdulkarim

et al., 2020). The economic evaluation of solar PV systems with the use of levelized cost was deduced to be 0.398-0.743 USD per kWh in Lagos Metropolitan area (Enongene et al., 2019). The cost implication deduced for 14 different locations in Nigeria was found to be 0.0524-0.0607 \$/kWh with payback period of 10.18-10.42 years (O et al., 2021). Economic viability of Agbani city as well as its technology was simulated by adopting HOMER Pro software. Model of direct current via grid PV system aligned with Surrrette S-260 battery valued at 35.67 Kw serve as cheapest configuration with cost of 0.11 \$/kWh having 0.048 million dollars as Net Present Cost (Ene et al., 2021). Analysis of hybrid system in rural areas and towns of Northern Nigeria with the aid levelised cost depicts \$0.3480-0.3780 per kWh and \$0.378/kWh regarding interest rate. This value is lower compare to standalone diesel generating set (Adaramola et al., 2014). Similar study was done in Giri village base on hybrid of wind/solar energy system. The operational expenses incurred was \$4723 having cost of electricity of 0.11dollar per kWh at net present cost of one million dollars (Salisu et al., 2019). The usage of hybrid in health facility in Norther region was thoroughly assessed for optimum financial viability. Simulation outcome prove that solar/diesel generator/battery that have the following capacity; 2 kilowatt generator set, solar PV of 5.43 Kw, ten pieces of battery and 3.06 Kw converter give optimum values for cost of electricity (\$0.259 per kWh) and net present cost (\$16457) (Oladigbolu et al., 2021). An hybrid analysis of wind/solar energy costing in University of Ilorin depicted \$0.283 per kWh which is comparatively higher than the present electricity in Nigeria (Ariyo et al., 2018). This study investigates the economics potential in remote community of Nigeria for three sources of electricity namely diesel generating set, solar energy as well as electric connection to power grid and the outcome shows solar renewable energy is most economically viable system (Bugaje, 1999). The impact of climatic difference on the performance ratio and economic buoyance of solar PV system was conducted. It was emphasized that larger value of performance ratio had been identified in tropical savanna and monsoon compared to warm semi-arid and warm desert. As for the economic potentiality, the levelized cost of energy across climatic variation to be 0.21 Dollar per kWh <0.25 dollar per kWh for national grid tariff whereas mean net present value was 31,164 dollar (Hamisu Umar et al., 2021). Arowolo and Perez stressed the need to provide centralized solar PV system that fitted to market design as well as effective regulatory framework (Arowolo and Perez, 2020) Moreover, an installation of solar PV system by applying energy partitioning technique in regard to status of quality of life was scrutinized. At the end of research, life cycle cost using 20 years horizon was 10600 dollars for highest influence on life quality while the cos of energy was 033341 dollar per kWh (Ayodele and Ogunjuyigbe, 2015). The levelized cost of energy obtained in Northern part of Nigeria was \$0.103/kW h using HOMER software which is economically buoyant. This work illustrated the application of solar energy in rural community name as Vandeikya local council, Benue State for their hospital using HOMER software Pro version 3.13.8. The yearly mean insolation is 4.92 kWh per meter square and the outcome give NPC (Net Present Cost) amounted to 718308000 Naira. It was suggested that hybrid application will be economically viable (Kuhe et al., 2021). By evaluating through costing and benefit technique, an affordable solar energy was studied in Abuja base micro-grid system. The net

present value obtained was 320,897841 Naira while internal rate of return was estimated to be 17.5%. So it was affirmed that solar PV system was viable and could reduce emission effect on the climate changes (Izuchukwu and Peace, 2021).

Assessment on economic viability of incorporating roof-top PV system based on 9- h per day energy consumption for 3 building types in Nigeria was simulated using NREL's system advisor model application. It was estimated that 3.30, 7.00, and 15.25 kW give NPV values of 2330, 7947 and 8075 Dollars respectively while their equivalent payback period were 12.3, 12.3 and 18.2 years accordingly. Their levelized cost of electricity were 8, 3 and 3 cent per kWh respectively (Elinwa et al., 2021). The cost of adopting off-grid solar PV system was simulated in Jos. The cost of electricity estimated was 0.18 Dollar per kWh (COE), yearly life cycle cost assessment was 593.75 Dollar (ALCC) having life cycle cost of 101110.9 Dollars (LCC) (Akinsipe et al., 2021). In the analysis of economic viability of solar PV system using RTScreen software, those sites fall on higher latitude appear to be more profitable compared to low latitude sites. The cash flow cumulative obtained (CCF) in Gusau was 795.30 million in US Dollar with the cost of energy production worthy 66.74 US Dollars per MWh while NPV was 215 million US Dollar. Likewise, in Port Harcourt, CCF was 389.7 million US Dollar with NPV of 40 million US Dollar and the cost of energy production was 103.10 US Dollar per MWh (Njoku and Omeke, 2020).

By critically examine the studies above, none of the study use Feed-in- Tariff system (FiT) due to unavailability of effective tariff system and other financial incentive that could boost the deployment of renewable energy systems. As stated by scholars that FiT had been most valuable renewable energy policy that promotes the utilization of renewable energy systems (Shahmohammadi et al., 2015). Then this gap needs to be filled by adopting efficient financial scheme that will encourage the umpires in renewable energy business. Researchers should assist in designed the required scheme that in line with economic reality of our communities. As time pass, we shall reach the milestone for avoidable, dependable and sustainable energy system when all stakeholders did their part. The studies in this section were summarized in Table 2.

4. ASSESSMENT OF OFFSHORE SOLAR ENERGY RESOURCES

The potential of solar radiance was simulated to reflect monthly, seasonal and yearly variation as a platform to explore this enormous renewable energy source. The coastal part of Nigeria has a total area of 13000KM². Its longitude falls on 2° 45'-8° 35' E and the latitudes lies on 4° 10'-6° 20' this coastline experiences south westerly's. The map is depicted in Figure 1 with the blue portion indicate coastal part of Nigeria.

The ERA5-Land grided at 0.1 by 0.1 at a resolution of 9 Km was employed in this study by considered 2002-2021 hourly data sets for solar energy in offshore part of Nigeria as depicted in the blue colour section in map 1. Data obtained was processed in ARCGIS 10.3 by converting NETCDF file into raster map. Thereafter, actual solar irradiance values were extracted in joules which then

converted to kilowatt-hour per meter square. The annual mean values for the 20 years period were depicted in Table 3. Moreover, the mean, minimum, maximum, standard deviation and the variance for monthly solar radiance distributions were calculated for 2002, 2003 and 2004 which also reflected the mean seasonal changes from rainy season (March-September) to dry season (October-February) as for the 3 years selected in this work as depicted in Tables 4-6. The least monthly mean solar radiance occurred in August for 2002 and 2003 were 2.3803 kWhm⁻² and 1.8594 kWhm⁻² respectively while in 2004 the least value was 2.3171 kWhm⁻² in June.

Table 2: Summary of literatures on economic analysis

Location	Method	Source
Nigeria	HOMER	(Ohijeagbon and Ajayi, 2015).
Lagos State	Financial technique	(Babajide and Brito, 2021).
Nigeria	Hybrid	(Adesanya and Schelly, 2019).
Lagos, Onisha, Kano		(Okoye et al., 2016)
Maiduguri, Porth-Harcourt, Minna	Value cost	(Abdulkarim et al., 2020)
Lagos metropolity	Levilized cost	(Enongene et al., 2019).
Nigeria	Levilized cost	(O et al., 2021).
Agbani City	HOMER Pro	(Ene et al., 2021).
Nortern Nigeria	Levilized cost	(Adaramola et al., 2014).
Giri village	NPV	(Salisu et al., 2019)
Northern region	NPC	(Oladigbolu et al., 2021).
University of Ilorin	Levilized cost	(Ariyo et al., 2018)
Nigeria	Costing	(Bugaje, 1999).
Nigeria	Levilized cost	(Hamisu Umar et al., 2021).
Nigeria	Life cycle cost	[68]
Vandeika LG, Benue State	HOMER	(Kuhe et al., 2021).
Abuja	NPV	(Izuchukwu and Peace, 2021)
Nigeria	NPV	(Izuchukwu and Peace, 2021)
Jos, Plateu State	ALCC, LCC, COE	(Akinsipe et al., 2021).
Nigeria	CCF, NPV	(Njoku and Omeke, 2020).

Table 3: Annual mean solar irradiance for 2002-2021

Year	Annual mean solar irradiance	Algebraic annual solar radiation (kWhm ⁻²)
2002	3.9858	34,915.608
2003	3.9858	34,915.608
2004	3.8553	33,425.451
2005	3.6819	31,922.073
2006	3.5187	30,507.129
2007	3.7340	32,373.78
2008	3.1104	26,967.168
2009	3.6881	31,975.827
2010	3.5002	30,346.734
2011	3.8385	33,279.795
2012	3.5815	31,051.605
2013	3.8848	33,681.216
2014	3.2739	28,384.713
2015	3.4199	29,650.533
2016	3.8168	33,091.656
2017	3.6068	31,270.956
2018	3.7792	32,765.664
2019	3.5791	31,030.797
2020	3.7610	32,607.87
2021	3.9103	33,902.301

Maximum mean monthly solar radiance recorded in February for 2002 was 5.5278 kWhm⁻² and the maximum value for 2003 (June) was 5.116 kWhm⁻² having 4.6983 kWhm⁻² in 2004 (December). The result for seasonal changes depicts the dry season higher than wet season as expected through the 20 years span. Their mean solar radiance for dry season is 4.0272, 4.1958 and 4.1421 kWhm⁻² accordingly for 2002, 2003 and 2004 as well as their mean solar radiance for wet season give 3.8046, 3.6409 and 3.6518 kWhm⁻² respectively for 2002, 2003 and 2004. The algebraic annual solar radiance for 2002-2021 with highest occurred in 2002 and 2003 as 34,914.732 kWhm⁻² and the least was 26,967.168 kWhm⁻² in 2008. The Figures 2-4 show the map of distributions of mean monthly solar radiance occurred for 2002, 2003 and 2004 ranged from highest (Red, yellow,

Figure 1: Map of the study area (Nwilo et al., n.d.)



Figure 2: Distribution of solar energy for August and February 2002 respectively




Table 4: Analysis of solar radiance for 2002

Items	Mean	Maximum	Minimum	Standard deviation	Variance
January	4.4166	4.8701	3.4553	0.25207	0.06354
February	5.5278	5.7548	5.2445	0.12137	0.01473
March	4.8732	5.4426	4.1839	0.27273	0.07438
April	4.4468	5.0362	4.0784	0.19847	0.039391
May	4.0174	4.6169	3.3221	0.27214	0.074058
June	3.7400	4.5156	3.2807	0.20953	0.04390
July	3.3388	4.1735	2.9391	0.23046	0.05311
August	2.3808	3.0056	0.9434	0.47174	0.22254
September	3.8549	4.7792	3.1757	0.38294	0.14664
October	3.3326	4.2356	2.5089	0.33041	0.10917
November	2.9086	4.2907	2.0765	0.46246	0.21387
December	4.0040	4.6571	3.4823	0.26701	0.07130
Rainy season	3.8046	5.4426	0.9434	0.80274	0.64439
Dry season	4.0272	5.7548	2.0765	0.95724	0.91631
Annual value	3.9857	5.4426	0.9434	0.65057	0.42324

Table 5: Analysis of solar radiance for 2003

Items	Mean (kWh/m ²)	Maximum (kWh/m ²)	Minimum (kWh/m ²)	Standard deviation	Variance
January	4.4166	4.8701	3.4553	0.25207	0.06354
February	5.5278	5.7548	5.2445	0.12137	0.01473
March	4.8732	5.4426	4.1839	0.27273	0.074382
April	4.4468	5.0362	4.0784	0.19847	0.039391
May	4.0174	4.6169	3.3221	0.27214	0.074058
June	3.7400	4.5156	3.2807	0.20953	0.043901
July	3.3388	4.1735	2.9391	0.23046	0.053112
August	2.3803	3.0056	0.94343	0.47174	0.22254
September	3.8549	4.7792	3.1757	0.38294	0.14664
October	3.3326	4.2356	2.5089	0.33041	0.10917
November	2.9086	4.2907	2.0765	0.46246	0.21387
December	4.004	4.6571	3.4823	0.26701	0.071295
Rainy season	3.8046	5.4426	0.94343	0.80274	0.64439
Dry season	4.0272	5.7548	2.0765	0.95724	0.91631
Annual value	3.9857	5.4426	0.94343	0.65057	0.42324

Table 6: Analysis of solar radiance for 2004

Items	Mean (kWh/m ²)	Maximum (kWh/m ²)	Minimum (kWh/m ²)	Standard deviation	Variance
January	4.3000	4.9072	3.7378	0.25338	0.064201
February	4.4440	5.3242	3.8155	0.31389	0.098525
March	4.3190	5.0137	3.6318	0.27281	0.074428
April	3.8033	4.4814	3.3680	0.21063	0.044363
May	4.4863	5.0087	3.9788	0.19986	0.039944
June	2.3171	3.5861	1.4975	0.46454	0.21580
July	3.4492	3.9663	2.6382	0.27212	0.07405
August	3.6343	4.7182	2.7112	0.38142	0.14548
September	3.5588	4.6634	2.7145	0.38051	0.14479
October	3.1743	4.7466	1.4766	0.85378	0.72894
November	4.1200	4.6728	3.7079	0.21210	0.044985
December	4.6983	5.2486	4.4032	0.13805	0.019059
Rainy season	3.6518	5.0137	1.4748	0.73437	0.5393
Dry season	4.1421	5.3242	1.4766	0.68404	0.46791
Annual value	3.9199	4.6634	2.7145	0.22494	0.050596

light blue and deep blue colour (lowest) values across the coast of Nigeria economy zone as indicated in blue portion of map Figure 1. These huge resources could be harnessed to cater for epileptic power supply being experienced in the country as well as mitigate the effect of global warming as enshrined in the pact signed by the government. The hybrid of solar and wind energy can be deployed near offshore.

There are several studies that embarked on hybrid of solar PV system and other renewable energy source as explained in the study done by Idris et al (Idris et al., 2020). It is my hope that efficient configurations of hybrid will enhance the development of solar PV system and will be of utmost benefits to communities especially in rural areas as various projects had been achieved and still ongoing.

Figure 3: Distribution of solar energy for August and January 2003 respectively





Figure 4: Distribution of solar energy in June and December 2004 respectively



5. CONCLUSION AND RECOMMENDATION

Several literatures were extensively studied the assessment of solar energy PV system, analysis of cost implication of solar energy and the hybrid system. Their works was reviewed to lay emphasis on what to be done to improve, enhance, and utilize solar energy in Nigeria. These was discussed at the end of each section. It should be reiterated all six geo-political zones in Nigeria possess adequate solar irradiance for solar energy PV system generation with larger values in the Northern region. The offshore solar energy resources potential had been simulated which is viable for large scale solar harvesting. The least annual solar radiation occurred in 2008 and highest were recorded in 2002 and 2003. Summarily, improvement on present renewable energy policy, formulation of appropriate financial system, collaboration on research and development and the willingness of government to explore renewable energy means are necessary steps to actualize our dreams on renewable deployment.

Data repository for solar energy assessment in Nigeria should be developed and deployed for easy access for government, scholars, developers and investors. The universities, colleges, mono-technics and polytechnics should design their curriculum with incorporation of renewable energy as part of their general studies. Community sensitization and awareness should be programmed by the relevant agencies. An extensive tariff system should be designed by Energy Commission of Nigeria. Existing policy need to be tailored towards achieving rapid development on renewable energy system.

ACKNOWLEDGMENTS

All Praises and Adorations are due to Almighty Allah for His guidance. My regard to faculty of ocean engineering, technology and informatics Universiti Malaysia Terengganu (UMT). I am grateful to the UMT management for providing me with MIS (Malaysia International Scholarship) via the Ministry of Higher Education (MOHE).

REFERENCES

- Abdelrazik, M.K., Abdelaziz, S.E., Hassan, M.F., Hatem, T.M. (2022), Climate action: Prospects of solar energy in Africa. *Energy Reports*, 8, 11363-11377.
- Abdulkarim, H.T., Sansom, C.L., Patchigolla, K., King, P. (2020), Statistical and economic analysis of solar radiation and climatic data for the development of solar PV system in Nigeria. *Energy Reports*, 6, 309-316.
- Abdullahi, D., Renukappa, S., Suresh, S., Oloke, D. (2021), Barriers for implementing solar energy initiatives in Nigeria: An empirical study. *Smart and Sustainable Built Environment*, 11.3(2022):647-660.
- Abu-Rayash, A., Dincer, I. (2021), Development and analysis of an integrated solar energy system for smart cities. *Sustainable Energy Technologies and Assessments*, 46, 101170.
- Adaramola, M.S. (2014), Viability of grid-connected solar PV energy system in Jos, Nigeria. *International Journal of Electrical Power and Energy Systems*, 61, 64-69.
- Adaramola, M.S., Paul, S.S., Oyewola, O.M. (2014), Assessment of decentralized hybrid PV solar-diesel power system for applications in Northern part of Nigeria. *Energy for Sustainable Development*, 19(1), 72-82.
- Adeniji, A.E., Njah, A.N., Olusola, O.I. (2019), Phase synchronization between solar radiation and wind speed data from some locations across Nigeria via nonlinear recurrence measures. *Chinese Journal of Physics*, 61, 274-282.
- Adesanya, A.A., Schelly, C. (2019), Solar PV-diesel hybrid systems for the Nigerian private sector: An impact assessment. *Energy Policy*, 132, 196-207.
- Adewuyi, O.B., Shigenobu, R., Senjyu, T., Lotfy, M.E., Howlader, A.M. (2019), Multiobjective mix generation planning considering utility-scale solar PV system and voltage stability: Nigerian case study. *Electric Power Systems Research*, 168, 269-282.
- Agbo, E.P., Edet, C.O., Magu, T.O., Njok, A.O., Ekpo, C.M., Louis, H. (2021), Solar energy: A panacea for the electricity generation crisis in Nigeria. *Heliyon*, 7(5), e07016.
- Akinsipe, O.C., Moya, D., Kaparaju, P. (2021), Design and economic analysis of off-grid solar PV system in Jos-Nigeria. *Journal of Cleaner Production*, 287, 125055.

- Akinyele, D., Olatomiwa, L., Ighravwe, D.E., Babatunde, M.O., Monyei, C., Aikhuele, D. (2020), Optimal planning and electricity sharing strategy of hybrid energy system for remote communities in Nigeria. *Scientific African*, 10, e00589.
- Akinyele, D.O., Rayudu, R.K., Nair, N.K.C. (2017), Life cycle impact assessment of photovoltaic power generation from crystalline silicon-based solar modules in Nigeria. *Renewable Energy*, 101, 537-549.
- Akuru, U.B., Okoro, O.I., Maduko, C.F. (2015), Harnessing Nigeria's abundant solar energy potential using the DESERTEC model. *Journal of Energy in Southern Africa*, 26(3), 105-110.
- Aliyu, S., Zakari, A.S., Ismail, M., Ahmed, M.A. (2020), An artificial neural network model for estimating daily solar radiation in Northwest Nigeria. *FUOYE Journal of Engineering and Technology*, 5(2), 1-5.
- Anaba, S.A., Olubusoye, O.E. (2021), Determinants of use of solar energy as an alternative means of energy by small and medium enterprises in Lagos State, Nigeria. *Discover Sustainability*, 2(1), 29.
- Ariyo, B.O., Akorede, M.F., Omeiza, I.O.A., Amuda, S.A.Y., Oladeji, S.A. (2018), Optimisation analysis of a stand-alone hybrid energy system for the senate building, university of Ilorin, Nigeria. *Journal of Building Engineering*, 19, 285-294.
- Arowolo, W., Perez, Y. (2020), Market reform in the Nigeria power sector: A review of the issues and potential solutions. *Energy Policy*, 144, 111580.
- Ayodele, T.R., Ogunjuyigbe, A.S.O. (2015), Increasing household solar energy penetration through load partitioning based on quality of life: The case study of Nigeria. *Sustainable Cities and Society*, 18, 21-31.
- Ayodele, T.R., Ogunjuyigbe, A.S.O. (2017), Performance assessment of empirical models for prediction of daily and monthly average global solar radiation: The case study of Ibadan, Nigeria. *International Journal of Ambient Energy*, 38(8), 803-813.
- Ayodele, T.R., Ogunjuyigbe, A.S.O., Adeniran, O.A. (2019), Evaluation of solar powered water pumping system: the case study of three selected Abattoirs in Ibadan, Nigeria. *International Journal of Sustainable Engineering*, 12(1), 58-69.
- Ayodele, T.R., Ogunjuyigbe, A.S.O., Nwakanma, K.C. (2021), Solar energy harvesting on building's rooftops: A case of a Nigeria cosmopolitan city. *Renewable Energy Focus*, 38, 57-70.
- Babajide, A., Brito, M.C. (2021), Solar PV systems to eliminate or reduce the use of diesel generators at no additional cost: A case study of Lagos, Nigeria. *Renewable Energy*, 172, 209-218.
- Bamisile, O., Huang, Q., Xu, X., Hu, W., Liu, W., Liu, Z., Chen, Z. (2020), An approach for sustainable energy planning towards 100 % electrification of Nigeria by 2030. *Energy*, 197, 117172.
- Barau, A.S., Abubakar, A.H., Kiyawa, A.H.I. (2020), Not there yet: Mapping inhibitions to solar energy utilisation by households in african informal urban neighbourhoods. *Sustainability*, 12(3), 840.
- Bugaje, I.M. (1999), Remote area power supply in Nigeria: The prospects of solar energy. *Renewable Energy*, 18(4), 491-500.
- Chiemelu, N.E., Anejionu, O.C.D., Ndukwu, R.I., Okeke, F.I. (2021), Assessing the potentials of largescale generation of solar energy in Eastern Nigeria with geospatial technologies. *Scientific African*, 12, e00771.
- Chikwado, U., Imo, E., Polytechnic, S., Okwuchukwu, O. B., Technology, A. S., Chiazor, O. D., & Technology, A. S. (2021). Primary health centre roof-top solar energy system, *Journal of Multidisciplinary Engineering Science and Technology (JMEST)* ISSN: 2458-9403 Vol. 8 I. 8(5), 14205–14214.
- Chineke, T.C., Okoro, U.K. (2010), Application of sayigh "Universal Formula" for global solar radiation estimation in the Niger Delta region of Nigeria. *Renewable Energy*, 35(3), 734-739.
- Diemuodeke, E.O., Addo, A., Dabipi-Kalio, I., Oko, C.O.C., Mulugetta, Y. (2017), Domestic energy demand assessment of coastline rural communities with solar electrification. *Energy and Policy Research*, 4(1), 1-9.
- Elegbede, O., Kerr, J., Richardson, R., Sanou, A. (2021), Using a choice experiment to understand preferences in off-grid solar electricity attributes: The case of Nigerian households. *Energy for Sustainable Development*, 60, 33-39.
- Elinwa, U.K., Ogbaba, J.E., Agboola, O.P. (2021), Cleaner energy in Nigeria residential housing. *Results in Engineering*, 9, 100103.
- Ene, P.C., Okoh, C.C., Okoro, P.A., Egoigwe, S.V., Chike, K.C. (2021), Application of smart DC-Grid for efficient use of solar photovoltaic system in driving separately excited DC motor: Dynamic performance and techno-economic assessments. *Cleaner Engineering and Technology*, 4, 100136.
- Enongene, K.E., Abanda, F.H., Otene, I.J.J., Obi, S.I., Okafor, C. (2019), The potential of solar photovoltaic systems for residential homes in Lagos city of Nigeria. *Journal of Environmental Management*, 244, 247-256.
- Hamisu Umar, N., Bora, B., Banerjee, C., Gupta, P., Anjum, N. (2021), Performance and economic viability of the PV system in different climatic zones of Nigeria. *Sustainable Energy Technologies and Assessments*, 43, 100987.
- Idris, W.O., Ibrahim, M.Z., Albani, A. (2020), The status of the development of wind energy in Nigeria. *Energies*, 13(23), 6219.
- Ikejamba, E.C.X., Schuur, P. (2016), Locating solar and wind parks in South-Eastern Nigeria for maximum population coverage: A multi-step approach. *Renewable Energy*, 89, 449-462.
- Ilori, A., Mufutau, W., Idowu, O., Babawale, J. (2020), Analysis of solar energy utilization pattern in Ibadan, Oyo State, Nigeria. *Adeleke University Journal of Engineering and Technology*, 3(1), 27-35.
- Izuchukwu, O.O., Peace, A.E. (2021), Design of affordable solar photovoltaic systems in Nigeria: A cost implication analysis. *South Asian Journal of Social Studies and Economics*, 10(3), 27-37.
- Juanpera, M., Blechinger, P., Ferrer-Martí, L., Hoffmann, M.M., Pastor, R. (2020), Multicriteria-based methodology for the design of rural electrification systems. A case study in Nigeria. *Renewable and Sustainable Energy Reviews*, 133, 110243.
- Koyejo, O., Zorbarile, A. (2021), Application of agglomerative hierarchical clustering and logistic model development for assessing solar energy acceptability as an alternate energy option. *Global Journal of Engineering and Technology Advances*, 7(1), 103-112.
- Kuhe, A., Achirgbenda, V.T., Agada, M. (2021), Global solar radiation prediction for Makurdi, Nigeria, using neural networks ensemble. *Energy Sources, Part A: Recovery, Utilization and Environmental Effects*, 43(11), 1373-1385.
- Liu, R., Liu, M., Zhao, Y., Ma, Y., Yan, J. (2021), Thermodynamic study of a novel lignite poly-generation system driven by solar energy. *Energy*, 214, 119075.
- Luo, J., Zhuang, C., Liu, J., Lai, K.H. (2023), A comprehensive assessment approach to quantify the energy and economic performance of small-scale solar homestay hotel systems. *Energy and Buildings*, 279, 112675.
- Muzathik, A.M., Nik, W.B.W., Ibrahim, M.Z., Samo, K.B., Sopian, K., Alghoul, M.A. (2011), Daily global solar radiation estimate based on sunshine hours. *International Journal of Mechanical and Materials Engineering*, 6(1), 75-80.
- Ndanusa, M.B. (2020), Harnessing solar energy potential as an alternative source. *African Journal of Environment and Natural Science Research*, 3(4), 86-94.
- Njoku, H.O. (2016), Upper-limit solar photovoltaic power generation: Estimates for 2-axis tracking collectors in Nigeria. *Energy*, 95, 504-516.
- Njoku, H.O., Omeke, O.M. (2020), Potentials and financial viability of solar photovoltaic power generation in Nigeria for greenhouse

- gas emissions mitigation. *Clean Technologies and Environmental Policy*, 22(2), 481-492.
- Nnaji, E.C., Adgidzi, D., Dioha, M.O., Ewim, D.R.E., Huan, Z. (2019), Modelling and management of smart microgrid for rural electrification in sub-saharan Africa: The case of Nigeria. *Electricity Journal*, 32(10), 106672.
- Nwaji, G.N., Okoronkwo, C.A., Ogueke, N.V., Anyanwu, E.E. (2020), Investigation of a hybrid solar collector/nocturnal radiator for water heating/cooling in selected Nigerian cities. *Renewable Energy*, 145, 2561-2574.
- Nwilo, P.C., Badejo Badejo, O.T., Badejo, O.T. (n.d.), Impacts and Management of Oil Spill Pollution along the Nigerian Coastal Areas Geoid Modelling View project Current Modelling and Prediction View project Impacts and Management of Oil Spill Pollution along the Nigerian Coastal Areas. Available from: <https://www.researchgate.net/publication/242327944>
- Nwokolo, S.C., Ogbulezie, J.C., Ushie, O.J. (2023), A multi-model ensemble-based CMIP6 assessment of future solar radiation and PV potential under various climate warming scenarios. *Optik*, 285, 170956.
- Nymphas, E.F., Otunla, T.A., Adeniyi, M.O., Oladiran, E.O. (2012), Impact of the total solar eclipse of 29 March 2006 on the surface energy fluxes at Ibadan, Nigeria. *Journal of Atmospheric and Solar-Terrestrial Physics*, 80, 28-36.
- Obiwulu, A.U., Chendo, M.A.C., Erusiafe, N., Nwokolo, S.C. (2020), Implicit meteorological parameter-based empirical models for estimating back temperature solar modules under varying tilt-angles in Lagos, Nigeria. *Renewable Energy*, 145, 442-457.
- Ogueke, N.V., Ikpamezie, I.I., Anyanwu, E.E. (2016), The potential of a small hydro/photovoltaic hybrid system for electricity generation in FUTO, Nigeria. *International Journal of Ambient Energy*, 37(3), 256-265.
- Ogunmodimu, O., Okoroigwe, E.C. (2019), Solar thermal electricity in Nigeria: Prospects and challenges. *Energy Policy*, 128, 440-448.
- Ohijeagbon, O.D., Ajayi, O.O. (2015), Solar regime and LVOE of PV embedded generation systems in Nigeria. *Renewable Energy*, 78(2015), 226-235.
- Ohunakin, O.S., Adaramola, M.S., Oyewola, O.M., Fagbenle, R.O. (2014), Solar energy applications and development in Nigeria: Drivers and barriers. *Renewable and Sustainable Energy Reviews*, 32, 294-301.
- Ohunakin, O.S., Adaramola, M.S., Oyewola, O.M., Fagbenle, R.O. (2015), Solar radiation variability in Nigeria based on multiyear RegCM3 simulations. *Renewable Energy*, 74, 195-207.
- Okoro, O.I., Madueme, T.C. (2006), Solar energy: A necessary investment in a developing economy. *International Journal of Sustainable Energy*, 25(1), 23-31.
- Okoye, A., Ofang, I., Nwaji, G., Anyawu, E. (2020), Analysis of solar energy resource potential to supplement grid power in Nigeria. *IOSR Journal of Mechanical and Civil Engineering (IOSR-JMCE)*, 17(3), 49-55.
- Okoye, C.O., Bahrami, A., Atikol, U. (2018), Evaluating the solar resource potential on different tracking surfaces in Nigeria. *Renewable and Sustainable Energy Reviews*, 81, 1569-1581.
- Okoye, C.O., Taylan, O., Baker, D.K. (2016), Solar energy potentials in strategically located cities in Nigeria: Review, resource assessment and PV system design. *Renewable and Sustainable Energy Reviews*, 55, 550-566.
- Oladigbolu, J.O., Al-Turki, Y.A., Olatomiwa, L. (2021), Comparative study and sensitivity analysis of a standalone hybrid energy system for electrification of rural healthcare facility in Nigeria. *Alexandria Engineering Journal*, 60(6), 5547-5565.
- Olarewaju, R.O., Ogunjuyigbe, A.S.O., Ayodele, T.R., Yusuff, A.A., Mosesthe, T.C. (2021), An assessment of proposed grid integrated solar photovoltaic in different locations of Nigeria: Technical and economic perspective. *Cleaner Engineering and Technology*, 4, 100149.
- Olatomiwa, L., Mekhilef, S., Shamshirband, S., Petković, D. (2015), Adaptive neuro-fuzzy approach for solar radiation prediction in Nigeria. *Renewable and Sustainable Energy Reviews*, 51, 1784-1791.
- Onwe, C.A., Rodley, D., Reynolds, S. (2020), Modelling and simulation tool for off-grid PV-hydrogen energy system. *International Journal of Sustainable Energy*, 39(1), 1-20.
- Owolabi, A.B., Nsafon, B.E.K., Huh, J.S. (2019), Validating the techno-economic and environmental sustainability of solar PV technology in Nigeria using RETScreen Experts to assess its viability. *Sustainable Energy Technologies and Assessments*, 36, 100542.
- Ozoegwu, C.G. (2018), The solar energy assessment methods for Nigeria: The current status, the future directions and a neural time series method. *Renewable and Sustainable Energy Reviews*, 92, 146-159.
- Ozoegwu, C.G., Akpan, P.U.O. (2021), Solar energy policy directions for safer and cleaner development in Nigeria. *Energy Policy*, 150, 112141.
- Salihu, T.Y., Akorede, M.F., Abdulkarim, A., Abdullateef, A.I. (2020), Off-grid photovoltaic microgrid development for rural electrification in Nigeria. *Electricity Journal*, 33(5), 106765.
- Salisu, S., Mustafa, M.W., Olatomiwa, L., Mohammed, O.O. (2019), Assessment of technical and economic feasibility for a hybrid PV-wind-diesel-battery energy system in a remote community of north central Nigeria. *Alexandria Engineering Journal*, 58(4), 1103-1118.
- Shahmohammadi, M.S., Yusuff, R.M., Keyhanian, S., Shakouri, H. (2015), A decision support system for evaluating effects of Feed-in Tariff mechanism: Dynamic modeling of Malaysia's electricity generation mix. *Applied Energy*, 146, 217-229.
- Thompson, O.A., Ajiboye, B.O., Oluwamide, A.D., Oyenike, O.O. (2021), Analysis of factors influencing households' preference level for solar energy in urban areas of southwest Nigeria. *International Journal of Energy Economics and Policy*, 11(3), 468-476.
- Wang, J., Han, Z., Liu, Y., Zhang, X., Cui, Z. (2021), Thermodynamic analysis of a combined cooling, heating, and power system integrated with full-spectrum hybrid solar energy device. *Energy Conversion and Management*, 228, 113596.
- Wu, Y., Li, C., Tian, Z., Sun, J. (2020), Solar-driven integrated energy systems: State of the art and challenges. *Journal of Power Sources*, 478, 228762.
- Yohanna, J.K., Itodo, I.N., Umogbai, V.I. (2011), A model for determining the global solar radiation for Makurdi, Nigeria. *Renewable Energy*, 36(7), 1989-1992.